


Initial Bid Package
New Chiller Plant,
3-750 ton Chillers,
Cooling Towers & Pumps

16" Chilled Water Mains to
ASC, ARW & ADR. Plate & Frame
Heat Exchanger in each bldg.

Extend 16" Chilled Water Main to
NPB, add Plate & Frame Heat
Exchanger in NPB.

Extend Chilled Water Main to Stadium

Tunnel from Existing Rotunda Lane
Tunnel to ADR, ASC & NPB,
w/ 2 parallel 10" Steam Lines
and 4" Condensate Lines.



Legend

- Chilled Water
- Steam Tunnel

| No. | Revision/Issue | Date |
|-----|----------------|------|
| | | |

| | | |
|-------------|--|------|
| Elec | | |
| Mech | | |
| Civil | | |
| Acrh | | |
| Approved By | | Date |

Facilities & Services—Engineering
Brookings, SD 57006

Project Name and Address
Utility Tunnel — Steam/Condensate
Infrastructure Repairs & Modernization
Attachment #2
November 2013

| | |
|----------------|----------|
| CAD File | Sheet |
| Project Number | |
| Date | 11/13/13 |
| Scale | As Noted |